



Ring main configuration: N56 single unit Hot flow to building. Temper at point of use if Cold supply set temp. ≥ 60 °C.-Fit UV steriliser to return if set temp. <60 °C. R1071 Pump Cable Building return-**Expansion control** valve to waste UV steriliser suitable for hot / Circulating pump / Expansion vessel if required water if set temperature <60 °C Max. current draw 2 A@230 V Size to AS/NZS 3500.4:2018 Appendix P

Ring main configuration: N56 Demand Direct



